

CIRCUIT BALANCING VALVES | MINI SWEAT |

MODEL CBV-MS (½" and ¾") | SUBMITTAL

File no: 36.50

Date: JUNE 30, 2016

Supersedes: 36.50

Date: NOVEMBER 14, 2002

MODEL NUMBER	QUANTITY RE	QUANTITY REQUIRED		IDENTIFICATION		
Contractor:		Approved by:		Date:		
Engineer:		Submitted by:	Submitted by:			
		Ordered by:		Date:		
JOD:		Representative:	Representative:			


SPECIFICATION

Connection: Solder Joint

Material of Construction: Brass


Maximum Working Pressure: 300 psi (2068 kPa) **Maximum Operating Temperature:** 250°F (121°C)


Handwheel: 1 Turn 360°



INSTALLATION

Generally locate the valve five pipe diameters downstream from a fitting, with two diameters downstream from the balancing valve free from fittings. If a balancing valve is located downstream from a circulation pump, allow a distance of 10 diameters between the pump and balancing valves (as illustrated).





DIMENSIONS

MODEL	PIPE SIZE	Α	В	С	WEIGHT
CBV-½" MS	1/2"	3.12 (79)	3.53 (90)	1.34 (34)	1.1 (0.5)
CBV-3/4" MS	3/4''	3.78 (96)	3.62 (92)	1.34 (34)	1.19 (0.54)

NOTE: All dimensions are in inches (mm) and weights in lbs. (kg)

- 1 Solder style models are supplied unassembled. Valve body must be soldered in the line before assembly.
- 2 Refer to Cv curves for sizing and balancing, giving pressure drop at different settings and flow rates.
- 3 Suggested meters for use in conjunction with Armstrong CBV's are the CBM-60 and CBVM-135/60
- 4 All valves furnished with probe metering ports.

TORONTO

23 BERTRAND AVENUE TORONTO, ONTARIO CANADA M1L 2P3 +1 416 755 2291

BUFFALO

93 EAST AVENUE NORTH TONAWANDA, NEW YORK U.S.A. 14120-6594 +1 716 693 8813

BIRMINGHAM

HEYWOOD WHARF, MUCKLOW HILL HALESOWEN, WEST MIDLANDS UNITED KINGDOM B62 8DJ +44 (0) 8444 145 145

MANCHESTER

WOLVERTON STREET
MANCHESTER
UNITED KINGDOM
M11 2ET
+44 (0) 8444 145 145

BANGALORE

#59, FIRST FLOOR, 3RD MAIN MARGOSA ROAD, MALLESWARAM BANGALORE, INDIA 560 003 +91 (0) 80 4906 3555

SHANGHAI

NO. 1619 HU HANG ROAD, XI DU TOWNSHIP FENG XIAN DISTRICT, SHANGHAI P.R.C. 201401 +86 21 3756 6696

SÃO PAULO

RUA JOSÉ SEMIÃO RODRIGUES AGOSTINHO, 1370 GALPÃO 6 EMBU DAS ARTES SAO PAULO, BRAZIL +55 11 4781 5500

ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

ARMSTRONGFLUIDTECHNOLOGY.COM

